

Technical Service Report

Date 15/12/23

Dealer GHS

Site Name Cofi House chatswood

Site Address "T12/ 436 Victoria Ave,
Chatswood"

Warranty Yes ~~No~~

Issue High Temp.

Technician Dojin Jung

Model TBP1200-2

Serial Number R4ABP1220G408

Fixed Yes

Work done to fix

High temperature due to gas
leak. Gas recharging.

Spare parts used -